




Rytons Building Products Ltd

RYTONS LOUVRE VENTILATORS, MULTIFIX AIR BRICK, AIRCORES, TELESCOPIC AIRLINERS, COWLS, HIT AND MISS VENTILATORS AND FLOOR VENTILATOR (BBA CERTIFICATE No 94/3071) IRISH BUILDING REGULATIONS STATEMENT



- THIS STATEMENT RELATES TO RYTONS LOUVRE VENTILATORS, MULTIFIX AIR BRICK, AIRCORES, TELESCOPIC AIRLINERS, COWLS, HIT AND MISS VENTILATORS AND FLOOR VENTILATOR AND SETS OUT THE OPINION OF THE BBA ON THE POSITION OF THE PRODUCT UNDER THE BUILDING REGULATIONS IN THE REPUBLIC OF IRELAND.
- It must be read in conjunction with Certificate No 94/3071.
- It will remain valid provided BBA Certificate No 94/3071 is valid.

The Building Regulations 1997/2000 Ireland

In the opinion of the BBA, Rytons Louvre Ventilators, Multifix Air Brick, AirCores, Telescopic AirLiners, Cowls, Hit and Miss Ventilators and Floor Ventilator, if used in accordance with the provisions of Certificate No 94/3071, will satisfy or contribute to satisfying the relevant requirements.

Requirement:	B2	Internal fire spread (linings)
Comment:		Wall-mounted products need not be considered as subject to this Requirement. See section 10.1 of BBA Certificate No 94/3071.
Requirement:	B4	External fire spread
Comment:		Wall-mounted products constitute unprotected areas and may be used within otherwise protected areas. See section 10.2 of BBA Certificate No 94/3071.
Requirement:	C4	Resistance to weather and ground moisture
Comment:		Externally-mounted products will not affect the ability of a wall to meet this Requirement.
Requirement:	D1	Materials and workmanship
Comment:		The products are acceptable. See section 12 of BBA Certificate No 94/3071.
Requirement:	F1	Means of ventilation
Comment:		The products can meet this Requirement. See section 8.2 of BBA Certificate No 94/3071.

On behalf of the British Board of Agrément

Date: 31st January 2003

Chief Executive