

Laboratory airborne sound insulation testing of Rytons Building Products Ltd ventilator systems



**Laboratory measurement of airborne sound insulation of small building elements**  
**Element-normalized level difference according to BS EN 20140-10:1992**  
**BRE horizontal transmission suite (B9 051-053)**

**Client:** Rytons Building Products Ltd

**Test date:** 23/07/2007

**Test number:** L107-157

**Test element:** Ventilator

0578

**Filler wall area:** 9.8 m<sup>2</sup>

**Description:**

TALHMCW ventilator assembly;

x1 MFAB96, TAL8000 AirLiner, HM85F Internal (OPEN), ABC6 Cowl

**Source room volume:** 130 m<sup>3</sup>

**Air temperature:** 19 °C

**Receive room volume:** 115 m<sup>3</sup>

**Air relative humidity:** 74 %

| Frequency<br>(Hz) | Reverberation<br>time<br>(s) | Background<br>level<br>(dB) | Source<br>level<br>(dB) | Receive<br>level<br>(dB) | $D_{n,e}$<br>(dB) |
|-------------------|------------------------------|-----------------------------|-------------------------|--------------------------|-------------------|
| 50                | 3.14                         | 24.8                        | 92.4                    | 59.2                     | 36.8              |
| 63                | 2.21                         | 16.1                        | 100.4                   | 67.9                     | 34.5              |
| 80                | 1.83                         | 13.4                        | 99.4                    | 64.0                     | 36.7              |
| 100               | 1.67                         | 14.4                        | 100.1                   | 60.6                     | 40.4              |
| 125               | 2.03                         | 10.9                        | 102.9                   | 66.4                     | 37.6              |
| 160               | 1.87                         | 20.7                        | 102.2                   | 62.9                     | 39.4              |
| 200               | 1.87                         | 36.1                        | 102.2                   | 63.9                     | 38.3              |
| 250               | 1.72                         | 14.3                        | 100.1                   | 64.9                     | 34.8              |
| 315               | 1.68                         | 12.6                        | 100.0                   | 66.1                     | 33.4              |
| 400               | 1.61                         | 20.7                        | 99.6                    | 64.2                     | 34.8              |
| 500               | 1.66                         | 8.9                         | 98.9                    | 63.8                     | 34.6              |
| 630               | 1.60                         | 9.6                         | 98.5                    | 59.8                     | 38.0              |
| 800               | 1.47                         | 9.9                         | 97.5                    | 58.8                     | 37.7              |
| 1,000             | 1.45                         | 16.9                        | 96.3                    | 51.1                     | 44.2              |
| 1,250             | 1.51                         | 12.6                        | 98.2                    | 51.3                     | 46.1              |
| 1,600             | 1.48                         | 5.8                         | 98.9                    | 50.1                     | 47.8              |
| 2,000             | 1.52                         | 6.2                         | 97.4                    | 46.4                     | 50.1              |
| 2,500             | 1.50                         | 6.9                         | 97.8                    | 42.2                     | 54.6              |
| 3,150             | 1.45                         | 8.5                         | 97.9                    | 38.1                     | 58.7              |
| 4,000             | 1.38                         | 10.1                        | 98.7                    | 40.2                     | 57.2              |
| 5,000             | 1.26                         | 8.3                         | 95.7                    | 36.1                     | 58.0              |

x Adjusted for flanking transmission

o Correction = 1.3 dB

Rating according to BS EN ISO 717-1:1997


|   |                                  |                                  |                                   |
|---|----------------------------------|----------------------------------|-----------------------------------|
| $D_{n,e,w}(C;C_{tr}) = 42 (-1;-3) \text{ dB}$ | $C_{50-3150} = -1 \text{ dB}$    | $C_{50-5000} = 0 \text{ dB}$     | $C_{100-5000} = 0 \text{ dB}$     |
|   | $C_{tr,50-3150} = -3 \text{ dB}$ | $C_{tr,50-5000} = -3 \text{ dB}$ | $C_{tr,100-5000} = -3 \text{ dB}$ |

Evaluation based on laboratory measurement results obtained by an engineering method

Based on the data provided in BS EN 20140-2:1993 it is estimated that the measurement uncertainty should not exceed  $\pm 1 \text{ dB}$  for the single-number quantity ( $D_{n,e,w}$ ) and should not exceed the values in Table A1 of BS EN 20140-2:1993 for the data in the individual third octaves ( $D_{n,e,w}$ )

This page may only be distributed with the test report in its entirety and in accordance with the terms and conditions of the contract

Laboratory airborne sound insulation testing of Rytons Building Products Ltd ventilator systems



Laboratory measurement of airborne sound insulation of small building elements  
 Element-normalized level difference according to BS EN 20140-10:1992  
 BRE horizontal transmission suite (B9 051-053)

Client: Rytons Building Products Ltd

Test date: 23/07/2007

Test number: L107-157

Test element: Ventilator

0578

Filler wall area: 9.8 m<sup>2</sup>

Description:

TALHMCW ventilator assembly;  
 x1 MFAB96, TAL8000 AirLiner, HM85F Internal (OPEN), ABC6 Cowl


Source room volume: 130 m<sup>3</sup>

Air temperature: 19 °C

Receive room volume: 115 m<sup>3</sup>

Air relative humidity: 74 %

| Frequency (Hz) | $D_{n,e}$ One-third octave (dB) |
|----------------|---------------------------------|
| 50             | 36.8                            |
| 63             | 34.5                            |
| 80             | 36.7                            |
| 100            | 40.4                            |
| 125            | 37.6                            |
| 160            | 39.4                            |
| 200            | 38.3                            |
| 250            | 34.8                            |
| 315            | 33.4                            |
| 400            | 34.8                            |
| 500            | 34.6                            |
| 630            | 38.0                            |
| 800            | 37.7                            |
| 1,000          | 44.2                            |
| 1,250          | 46.1                            |
| 1,600          | 47.8                            |
| 2,000          | 50.1                            |
| 2,500          | 54.6                            |
| 3,150          | 58.7                            |
| 4,000          | 57.2                            |
| 5,000          | 58.0                            |



x Adjusted for flanking transmission

o Correction = 1.3 dB

Rating according to BS EN ISO 717-1:1997

$D_{n,e,w}(C; C_{tr}) = 42 (-1; -3) \text{ dB}$      $C_{50-3150} = -1 \text{ dB}$      $C_{50-5000} = 0 \text{ dB}$      $C_{100-5000} = 0 \text{ dB}$   
 $C_{tr,50-3150} = -3 \text{ dB}$      $C_{tr,50-5000} = -3 \text{ dB}$      $C_{tr,100-5000} = -3 \text{ dB}$

Evaluation based on laboratory measurement results obtained by an engineering method

Based on the data provided in BS EN 20140-2:1993 it is estimated that the measurement uncertainty should not exceed  $\pm 1 \text{ dB}$  for the single-number quantity ( $D_{n,e,w}$ ) and should not exceed the values in Table A1 of BS EN 20140-2:1993 for the data in the individual third octaves ( $D_{n,e,w}$ )

This page may only be distributed with the test report in its entirety and in accordance with the terms and conditions of the contract

Laboratory airborne sound insulation testing of Rytons Building Products Ltd ventilator systems



Laboratory measurement of airborne sound insulation of small building elements  
Element-normalized level difference according to BS EN 20140-10:1992  
BRE horizontal transmission suite (B9 051-053)

Client: Rytons Building Products Ltd  
Test date: 23/07/2007 Test number: L107-158 Test element: Ventilator

0578

Filler wall area: 9.8 m<sup>2</sup>

Description:

TALHMCW ventilator assembly;  
x1 MFAB96, TAL8000 AirLiner, HM85F Internal (CLOSED), ABC6 Cowl

Source room volume: 130 m<sup>3</sup>

Air temperature: 19 °C

Receive room volume: 115 m<sup>3</sup>

Air relative humidity: 74 %

| Frequency<br>(Hz) | Reverberation<br>time<br>(s) | Background<br>level<br>(dB) | Source<br>level<br>(dB) | Receive<br>level<br>(dB) | $D_{n,e}$<br>(dB) |
|-------------------|------------------------------|-----------------------------|-------------------------|--------------------------|-------------------|
| 50                | 3.14                         | 23.9                        | 91.5                    | 58.8                     | 36.3              |
| 63                | 2.21                         | 16.5                        | 99.8                    | 68.2                     | 33.6              |
| 80                | 1.83                         | 13.2                        | 99.4                    | 64.1                     | 36.6              |
| 100               | 1.67                         | 14.4                        | 100.1                   | 60.7                     | 40.3              |
| 125               | 2.03                         | 10.5                        | 102.9                   | 66.3                     | 37.7              |
| 160               | 1.87                         | 20.2                        | 102.2                   | 62.7                     | 39.6              |
| 200               | 1.87                         | 35.7                        | 102.2                   | 63.8                     | 38.4              |
| 250               | 1.72                         | 14.3                        | 100.0                   | 64.6                     | 35.2              |
| 315               | 1.68                         | 12.6                        | 100.1                   | 66.0                     | 33.7              |
| 400               | 1.61                         | 21.3                        | 99.6                    | 64.2                     | 34.9              |
| 500               | 1.66                         | 9.2                         | 98.9                    | 63.3                     | 35.1              |
| 630               | 1.60                         | 9.5                         | 98.5                    | 59.2                     | 38.7              |
| 800               | 1.47                         | 9.9                         | 97.5                    | 58.3                     | 38.2              |
| 1,000             | 1.45                         | 16.7                        | 96.4                    | 51.1                     | 44.3              |
| 1,250             | 1.51                         | 13.0                        | 98.2                    | 51.7                     | 45.7              |
| 1,600             | 1.48                         | 5.8                         | 98.9                    | 50.2                     | 47.8              |
| 2,000             | 1.52                         | 6.2                         | 97.4                    | 46.2                     | 50.3              |
| 2,500             | 1.50                         | 6.9                         | 97.8                    | 41.4                     | 55.4              |
| 3,150             | 1.45                         | 8.4                         | 97.9                    | 36.9                     | 60.0              |
| 4,000             | 1.38                         | 10.0                        | 98.6                    | 36.7                     | 60.6              |
| 5,000             | 1.26                         | 8.4                         | 95.7                    | 32.3                     | 61.8              |


x Adjusted for flanking transmission

o Correction = 1.3 dB

|   |                               |                              |                               |                                   |                                  |
|---|-------------------------------|------------------------------|-------------------------------|-----------------------------------|----------------------------------|
| Rating according to BS EN ISO 717-1:1997  |                               |                              |                               |                                   |                                  |
| $D_{n,e,w}(C;C_{tr}) = 42 (-1;-2) \text{ dB}$   | $C_{50-3150} = -1 \text{ dB}$ | $C_{50-5000} = 0 \text{ dB}$ | $C_{100-5000} = 0 \text{ dB}$ | $C_{tr,50-3150} = -3 \text{ dB}$  | $C_{tr,50-5000} = -3 \text{ dB}$ |
|   |                               |                              |                               | $C_{tr,100-5000} = -2 \text{ dB}$ |                                  |
| Evaluation based on laboratory measurement results obtained by an engineering method  |                               |                              |                               |                                   |                                  |
| Based on the data provided in BS EN 20140-2:1993 it is estimated that the measurement uncertainty should not exceed $\pm 1 \text{ dB}$ for the single-number quantity ( $D_{n,e,w}$ ) and should not exceed the values in Table A1 of BS EN 20140-2:1993 for the data in the individual third octaves ( $D_{n,e,w}$ ) |                               |                              |                               |                                   |                                  |

This page may only be distributed with the test report in its entirety and in accordance with the terms and conditions of the contract

Laboratory airborne sound insulation testing of Rytons Building Products Ltd ventilator systems



Laboratory measurement of airborne sound insulation of small building elements  
 Element-normalized level difference according to BS EN 20140-10:1992  
 BRE horizontal transmission suite (B9 051-053)

Client: Rytons Building Products Ltd  
 Test date: 23/07/2007 Test number: L107-158 Test element: Ventilator

0578

Filler wall area: 9.8 m<sup>2</sup>

Description:

TALHMCW ventilator assembly;  
 x1 MFAB96, TAL8000 AirLiner, HM85F Internal (CLOSED), ABC6 Cowl


Source room volume: 130 m<sup>3</sup>

Air temperature: 19 °C

Receive room volume: 115 m<sup>3</sup>

Air relative humidity: 74 %

| Frequency (Hz) | $D_{n,e}$ One-third octave (dB) |
|----------------|---------------------------------|
| 50             | 36.3                            |
| 63             | 33.6                            |
| 80             | 36.6                            |
| 100            | 40.3                            |
| 125            | 37.7                            |
| 160            | 39.6                            |
| 200            | 38.4                            |
| 250            | 35.2                            |
| 315            | 33.7                            |
| 400            | 34.9                            |
| 500            | 35.1                            |
| 630            | 38.7                            |
| 800            | 38.2                            |
| 1,000          | 44.3                            |
| 1,250          | 45.7                            |
| 1,600          | 47.8                            |
| 2,000          | 50.3                            |
| 2,500          | 55.4                            |
| 3,150          | 60.0                            |
| 4,000          | 60.6                            |
| 5,000          | 61.8                            |



x Adjusted for flanking transmission

o Correction = 1.3 dB

Rating according to BS EN ISO 717-1:1997

$D_{n,e,w}(C; C_{tr}) = 42 (-1; -2)$  dB  
 $C_{50-3150} = -1$  dB       $C_{50-5000} = 0$  dB       $C_{100-5000} = 0$  dB  
 $C_{tr,50-3150} = -3$  dB       $C_{tr,50-5000} = -3$  dB       $C_{tr,100-5000} = -2$  dB

Evaluation based on laboratory measurement results obtained by an engineering method

Based on the data provided in BS EN 20140-2:1993 it is estimated that the measurement uncertainty should not exceed  $\pm 1$  dB for the single-number quantity ( $D_{n,e,w}$ ) and should not exceed the values in Table A1 of BS EN 20140-2:1993 for the data in the individual third octaves ( $D_{n,e,w}$ )

This page may only be distributed with the test report in its entirety and in accordance with the terms and conditions of the contract

bre

**Laboratory airborne  
sound insulation testing  
of Rytons Building  
Products Ltd ventilator  
systems**

Prepared for: Karen Jolley

Rytons Building Products Ltd

20 August 2007

Test report number 238655



0578

building a better world