



Technical Report



INVESTOR IN PEOPLE

Report Number C/08/5L/20186/R01

Date 13 May 2008

Project

**The Laboratory Determination of
The Element Normalised Level Difference
of Various Ventilators**

Prepared for

**Titon Hardware Ltd
International House
Peartree Road
Stanway
Colchester
Essex CO3 0JL**

By

Allen Smalls

Sound Research Laboratories Limited

Consultants in Noise & Vibration

Head Office & Laboratory: Holbrook House, Little Waldingfield

Sudbury, Suffolk CO10 0TH

Telephone (01787) 247595 Fax (01787) 248420

e-mail: srl@soundresearch.co.uk

*This report shall not be reproduced, except in full,
without written approval of the laboratory*

1.0 Summary

Tests have been done in SRL's Laboratory at Holbrook House, Sudbury, Suffolk, to determine the element normalised level difference of various ventilators in accordance with BS EN 20140-10:1992, ISO 140-10:1991

From these measurements the required results have been derived and are presented in both tabular and graphic form in Data Sheets 1 to 39.

The results are given in 1/3rd octave bands over the frequency range 100Hz to 10kHz, which is beyond that required by the test standard.



.....
Allen Smalls
Laboratory Manager
Quality Manager



.....
Trevor Hickman
Executive Consultant
Deputy Technical Manager

For and on behalf of
Sound Research Laboratories Ltd

